

Nr.	Plassering	Tag	Type	Info	Fuse
1	Deadship Gen Rom	814-JB-210	F&G	F&G + ESD	
1	Deadship Gen Rom	814-JB-004B	ESD	ESD 1+2	
1	Deadship Gen Rom	875-EN-P02-4007	Power	440V	25 A
1	Deadship Gen Rom	DCU-JB-001	Power	230V 1 fas	16 A
1	Deadship Gen Rom	RP-L14-15-06	Power	230V 1 fas	16 A
1	Lifestation Fwd	425-JB-010A	PAGA	PA A	
1	Lifestation Fwd	425-JB-330B	PAGA	PA B	
1	Lifestation Fwd	JB-D41-08-11	Power	230V 1 fas	16 A
1	Lifestation Fwd	425-JB-704	Tele/Data	Fiber	
1	Lifestation Fwd	425-JB-154A	PAGA	PA A	
1	Lifestation Fwd	425-JB-063B	PAGA	PA B	
1	Lifestation Fwd	JB-D-21-01-04	Power	230V 1 fas	16A
2	Riser deck stb fwd corner	874-EX-001	Power	690V	63 A
2	Riser deck stb fwd corner	875-EN-P02-4008	Power	440V	50A
2	Riser deck stb fwd corner	814-JB-620	F&G	F&G + ESD 1+2	
2	Riser deck stb fwd corner	JB-L24-19-01	Power	230V 1 fas	16A
2	Riser deck stb fwd corner	375-JB-010	Signal	F&G	
2	Riser deck stb fwd corner	875-EX-007	Power	440V	50A
2	Riser deck stb fwd corner	RP-D42-17-06	Power	230V 1 fas	16 A
2	Riser deck stb fwd corner	RP-D31-23-05	Power	230V 1 fas	16A
3	Riser deck port aft corner	814-JB-622	Signal	F&G + ESD 1+2	
3	Riser deck port aft corner	RP-L14-34-01	Power	230V 1 fas	16A
3	Riser deck port aft corner	RP-L14-34-02	Power	230V 1 fas	16A
3	Riser deck port aft corner	RP-L14-36-01	Power	230V 1 fas	16A
3	Riser deck port aft corner	RP-L14-36-02	Power	230V 1 fas	16A
4	Handling area port (Torget)	875-EN-P0604-JB3	Power	440V	40
4	Handling area port (Torget)	814-JB-006	Signal	F&G ESD 1	
4	Handling area port (Torget)		Tele/Data	copper	
4	Handling area port (Torget)		PAGA	PAGA A+B	
4	Handling area port (Torget)	875-EX-009	Power	440V	50

4	Handling area port (Target)	RP-D32-18-07	Power	230V 1 fas	16 A
4	Handling area port (Target)	JB-D32-18-02	Power	230V 1 fas	16 A
5	Cuttings area port	874-jb-300	Power	440V	80 A
5	Cuttings area port	326-JB-115	Power	690 V	25 A
5	Cuttings area port	326-JB-116	Power	690 V	25 A
5	Cuttings area port	874-JB-013	Power	440V	50 A
5	Cuttings area port	874-JB-013	Power	230V 1 fas	16 A
5	Cuttings area port	874-JB-017	Power	440V	150 A
5	Cuttings area port	874-JB-017	Power	230V 1 fas	16 A
5	Cuttings area port	875-JB-P400-3	Power	440V	150
5	Cuttings area port	814-JB-582	Signal	ESD 1+2, F&G +alarm	
5	Cuttings area port	425-JB-705	Tele/Data	Fiber	
6	Port Aft	875-EX-008	Power	440V	50 A
6	Port Aft	875-JB-P400C	Power	440V	100 A
6	Port Aft	875-JB-P400C	Power	230V 1 fas	16 A
6	Port Aft	JB-L33-26-01	Power	230V 1 fas	16 A
6	Port Aft	RP-D32-17-03	Power	230V 1 fas	16 A
6	Port Aft	814-JB-020A	Signal	ESD1/2 + F&G	
7	Cement room...				
8	Welltest (naustet)	425-JB-409	Signal	CCTV	
8	Welltest (naustet)	375-JB-003		FMC + PSD	
8	Welltest (naustet)	JB-D31-Q31-01	Power	230v 3 fase	16A
8	Welltest (naustet)	RP-D42-17-01	Power	230V 1 fas	16A
8	Welltest (naustet)	814-JB-611	Signal	ESD 1M F&G+alarm	
8	Welltest (naustet)	874-JB-019	Power	440V	60
8	Welltest (naustet)	874-JB-501	Power	440V	100 A
8	Welltest (naustet)	874-JB-400	Power	440V	40
8	Welltest (naustet)	874-JB-400	Power	440V	60
8	Welltest (naustet)	874-JB-400	Power	440V	40 A
8	Welltest (naustet)	874-JB-400	Power	440V	30 A

8	Welltest (naustet)	425-JB-702	Tele/Data	Fiber	
8	Welltest (naustet)	JB-D31-28-01	Power	230V 1 fas	16A
8	Welltest (naustet)	JB: EDS/ESD WELLTEST		To: BOP Controll Cabinet	
8	Welltest (naustet)	814-JB-005	Signal	ESD 1, F&G	
8	Welltest (naustet)	814-JB-005	Tele/Data/PAGA	Data/Tele, PA A+B	
9	Kran Pidestal Stbd	814-JB-610	Signal	F&G + ESD	
9	Kran Pidestal Stbd	375-JB-013	PAGA	PA A/B	
9	Kran Pidestal Stbd	JB-L44-20	Power	230V 1 fas	16A
9	Kran Pidestal Stbd	375-JB-011	Tele/Data	Fiber	
9	Kran Pidestal Stbd	874-JB-400C	Power	440V	30
9	Kran Pidestal Stbd	875-EN-P02-4005/875-EX-006	Power	440V	50
9	Kran Pidestal Stbd	RP-D31-23-01	Power	230V 1 fas	16A
9	Kran Pidestal Stbd	874-JB-014	Power	690V	200
9	Kran Pidestal Stbd	874-JB-014	Power	230V 1 fas	16A
9	Kran Pidestal Stbd	874-JB-016B	Power	230V 1 fas	16A
9	Kran Pidestal Stbd	425-JB-02	Tele/Data	Fiber WLAN	
10	ROV area	425-JB-001	Tele/Data	Fiber WLAN	
10	ROV area	425-JB-374A	PAGA	PA A	
10	ROV area	425-JB-135B	PAGA	PA B	
10	ROV area	874-JB-018	Power	440V	40/60 A
10	ROV area	874-JB-007	Power	690 V	250 A
10	ROV area	874-JB-007	Power	230V 1 fas	16A
11	Wireline deck	814-JB-623	Signal	F&G, ESD 1+2	
11	Wireline deck	814-JB-624	Signal	F&G, ESD 1+2	
11	Wireline deck	425-JB-703	Tele/Data/CCTV	Copper X 12	
11	Wireline deck	814-JB-212	ESD/FG	2 Pair 1.5 mm2	
11	Wireline deck	425-JB-003	Tele/Data	Fiber	
11	Wireline deck	874-JB-008	Power	690V	100A
11	Wireline deck	874-JB-008	Power	230V 1 fas	16A
11	Wireline deck	874-JB-009	Power	440V	100A
11	Wireline deck	874-JB-009	Power	230V 1 fas	16A

11	Wireline deck	874-JB-010	Power	690V	160A
11	Wireline deck	874-JB-010	Power	230V 1 fas	16A
11	Wireline deck	814-JB-002	Signal	Tele/Data, PAGA a/b, CCTV	
11	Wireline deck	814-JB-002	Signal	F&G BN MODUL	
12	Sack Store Roof fwd	425-JO-801	Signal	Tele/Data switch 31	
12	Sack Store Roof fwd	375-JB-005	Signal	WOCS Unit	
12	Sack Store Roof fwd	814-JB-613	Signal	ESD, F&G+alarm	
12	Sack Store Roof fwd	814-JB-010	Signal	ESD, CCTV, COAX	
12	Sack Store Roof fwd	814-JB-010	PAGA	PA A/B	
12	Sack Store Roof fwd	WOCS UPS 1	Power	Power + Signal 12par	
12	Sack Store Roof fwd	874-JB-020	Power	440V	60
12	Sack Store Roof fwd	RP-D42-19-03	Power	230V 1 fas	16A
12	Sack Store Roof fwd	375-JB-001	Signal	WOCS Unit	
12	Sack Store Roof fwd	425-JB-701	Tele/Data	Fiber communication	
13	Sack Store Roof stbd	RP-d31-22-08	Power	230V 1 fas	16A
13	Sack Store Roof stbd	874-JB-012	Power	690V	80
13	Sack Store Roof stbd	874-JB-012	Power	230V 1 fas	16A
13	Sack Store Roof stbd	425-JB-410	CCTV	CCTV uttak	
13	Sack Store Roof stbd	814-JB-004	Signal	Data/tele, PAGA a/b	
13	Sack Store Roof stbd	814-JB-004	Signal	ESD 1 par	
13	Sack Store Roof stbd	814-JB-004	Signal	F&G 1 par	
13	Sack Store Roof stbd	814-JB-003	Tele/Data	Data/tele, LAN/tlf	
13	Sack Store Roof stbd	814-JB-003	Signal	ESD 1 par	
13	Sack Store Roof stbd	814-JB-003	Signal	F&G 1 par	
13	Sack Store Roof stbd	814-JB-003	PAGA	PA a/b	
13	Sack Store Roof stbd	WOCS UPS2	Power	Power, signal 12par	
13	Sack Store Roof stbd	814-JB-614	Signal	F&G+alarm, ESD	
13	Sack Store Roof stbd	814-JB-003A	Signal	ESD 1 par, PAGA, LAN	
13	Sack Store Roof stbd	874-JB-401	Power	690V/440V	80/100 A/30 A
13	Sack Store Roof stbd	874-JB-402	Power	230V 1 fas	16A

Supplied from	Info
P02 - Q7	Deler power med 875-EN-P02-4008 stb fwd riser deck.
L14-18	
L14-15	
D41-08	
A701 LAN	
D21-01-04	
MCC21 5.6	Deler power med 875-EN-P02-4007 stb fwd riser deck.
P02 - Q7	
L24-19	
P02 - Q6	
D42-17	
D31-23	
L14-34	
L14-34	
L14-36	
L14-36	
P06-Q04	
P09-2004	

D32-18
D-32-18
Koblet fra, P300 Q2
MCC 33-5.2
MCC43-4.2
P400-Q3
L43-12
P400-Q1
L43-19
P400-Q3
P09-Q03
P300-Q5
D41-23
L33-26
D32-17
D31-31
D42-17
P400-Q06
P400-Q4
P400-Q02
P400-Q08
P300-Q04
P300-Q06

Deler kurs med 874-JB-401 Sack Store roof



D31-28
Svart koblingsboks 1 par
FS61.1
L44-20
P400-Q09
P02-Q05
D31-23
MCC42 - 5.4
L47-24
L44-17
P300 CB 1+3
873ENM10-3208
L33-33
FS
FS
A701
Deadship gen rom 814-JB-210
MCC13 - 3.6
891-EL-L37-24
LS12 3.4
891-EL-L47-Q25

ROV Unit, fast oppkoblet  
ROV Unit, fast oppkoblet  
ROV Unit, fast oppkoblet

MCC13 - 4.4
891-EL-L13-Q16
LIR
FS61-1
Wocs intern kabling
P400-Q07
D42-19
Wocs intern kabling
D31-22
MCC21 - 5.6
L45-06
Wocs intern kabling
MCC21 - 2.7 / P400-Q4/P400-Q9
L35-04

SJEKK DWG

CD 006/CD007 Intern Wocs UPS oppkobling

LIR

CD 008 Intern Wocs UPS oppkobling